



VALSEAL LTD

8117 DAVIES ROAD
EDMONTON, ALBERTA
T6E 4N1

PHONE: (780) 438-2672 FAX: (780) 434-5166
www.valsealltd.com

INSPECTION REPORT

ASVS-1

ASVRA MEMBER

Order No.: 32266 Item No.: 43 VSL ID#: 002554
Date: 10/01/07 A#: P.O.No.: CRN
Customer Name: Trident Address: Fort Assiniboine
Manufacturer: Consolidated Size: 3/4" NPT Orifice: Serial No.: TP67039
Type: 19096MCF-2-GS-MS Temp: Capacity: 352.03 LPM Tag #: Glycol pump
Set Pressure: 1300 PSI B.P.: Reset Pressure: 1300 PSI
8957 KPA 8957 KPA

PARTICULARS - AS RECEIVED: Seal: Good Seal Id: BARBER

Visible Damage: None

Tag Condition: OK

Body: Dirty

Visible Condition:

Inlet: Oil

Outlet: Oil

Pretest: Leaks

KPA Simmer: 1300

Lift: 1300

Reseat: none

AFTER CLEANING AND INSPECTION:

Bonnet Cap: C.C.

Disc Seat: Flat

Disc Status: Pitted

Nozzle Seat: Pitted

Spring: No Number

Special Coating: No

Condition of Bellows: None

Internal Parts Damage:

Repairs Required: Machined and lapped seats.

Parts Installed: Gaskets

Parts To Be Ordered:

AFTER ASSEMBLY:

Test Pressure: KPA Simmer: 8957 Lift: 9136 Reseat: 8330

Back Pressure Test Accept Leakage as per manufacturer's spec or API 527 4 bpm cc/hr

COMMENTS: GLYCOL PUMP

Certified:.....

Date: 10/4/07.....

GLP

GP