

Certificate of Inspection Permit

HALTECH TESTING INC

PO BOX 48

BAYTREE, AB
T0H 0A0

Max. Inspection Interval: 4.00 Yr.

Year Built: 2011

CRN: V0730.2

Serial #: 1J115135

Volume: 12.200 M3

Heating Surface:

Surface Area:

COMPANY CODE: *PT-07*

DESCRIPTION: HORIZONTAL

LOCATION: PORTABLE, BAY TREE

MANUFACTURER: DYNACORP FABRICATORS INC

PART	MAX. ALLOWABLE PRESSURE	MAX. TEMP	MIN. TEMP	Pressure Relief Valves			
				VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	6895 KPA	204 C	-46 C	SV1	6890 KPA	669 M3/MIN	ON VESSEL

Terms and Conditions:

Owner must ensure this vessel/boiler, its overpressure protection devices, pressure gauges and regulating or controlling devices are maintained in good working order and operated safely.

Owner must ensure this vessel/boiler has overpressure protection that is a relief valve that meets the requirements of the ASME Code, or other means accepted by the Administrator expressly for this item.

Owner must ensure this vessel/boiler is designed, constructed, installed, operated, maintained and decommissioned in accordance with the Safety Codes Act and Regulations.

Pressure relief device is to be serviced by an authorized servicing company every two years.

Permit issued by: HOUSE, DAN D00009247

Signature: 

REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

An owner or vendor must notify the Administrator in writing when the pressure equipment identified on this certificate is sold or otherwise disposed of.

The owner or person in charge shall report all accidents involving Pressure Equipment to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.